



LAPI LABORATORIO PREVENZIONE INCENDI S.p.A.  
Sede Primaria: I-59100 PRATO - Via della Quercia, 11  
Telefono +39 0574.575.320 - Telefax +39 0574.575.323  
Sede Secondaria: I-50041 CALENZANO (FI) - Via Petrarca, 48  
e-mail: lapi@laboratoriolapi.it  
web site: www.laboratoriolapi.it

Reg. 305/2011  
Notified Body N°0987

## Certificate of Evaluation and Verification of Constancy of Performance 0987-CPR-221

In compliance with the Regulation UE 305/2011 on the approximation of law, regulations and administrative provisions of the Member States relating to the construction products, it has been stated that:

*the construction product denominated:*

**Linowall**

*Description of the product:*

**Panel used for wall and/or ceiling covering according to the definition of EN 15102: 2007 + A1:2011**



**Type:** Decorative wall coverings - Roll and panel form products  
**Use:** Decorative wall covering  
**End use:** Glued with polymer-based single-coat adhesive in water dispersion in ratio 300÷400 g/m<sup>2</sup>, to support of Euroclass A1 or A2. Type and brand of adhesive have been confidentially maintained at LAPI SpA.

*Produced by:*

**TARKETT S.p.A.**

**Strada Sant'Anna, 6 - 05035 NARNI SCALO (TR) - (Italy)**

*in the factory of:*

**Strada Sant'Anna, 6 - 05035 NARNI SCALO (TR) - (Italy)**

is submitted by the manufacturer to the factory production control (FPC) under **System 1** and to the testing of samples (ITT) by the Notified body for Certification, Inspection and Testing according to Regulation UE 305/2011.

The Notified Body (LAPI S.p.A. - Laboratorio Prevenzione Incendi N° 0987) has performed the initial type testing on the samples taken at the factory in accordance with the described test for the relevant characteristics of the product, the initial inspection of the factory and the factory production control and it will perform the continuous surveillance, assessment and approval of the factory production control.

This certificate attests that all provisions concerning to the **System 1** and the performances described in Annex ZA of the standard **EN 15102: 2007 + A1:2011**

**"Decorative wallcoverings - Roll and panel form products"**

are performed and the product complies with characteristics required as for:

EN 12149: 1997 Method A - Migration of heavy metals

EN 12149: 1997 Method C - Formaldehyde release

Moreover Euroclass for reaction to fire according to UNI EN 13501-1:2019 is:

**B - s2, d0**



This certificate was first issued on 16/12/2016. This renewal is issued on 16/12/2021 and it remains valid as long as the conditions laid down in the harmonised technical specification in reference or the manufacturing conditions in the factory or as long as the factory production control itself are not modified significantly and latest on 15/12/2026.

Prato, 16/12/2021

The Technical Director  
Dr. Luca Ermini